

# Proof Test Coverage User Guide

1. The Purpose of this tool to assist the user in determining the overall PTC to be used in the SILCalc tool. You will need the device certificate, operating manuals, safety manual, assessment reports, etc.. Depending on the certifying agency or vendor, the information needed may be found in one of these documents.
2. From the SILCals tool, select the devices for the sensor or final element group).

Process Connection	Sensor Device	Interface 1	Interface 2
None	Rosemount 3051C / 3051L, SW ...	Pepperl+Fuchs Standstill Controll...	Pepperl+Fuchs TB-HONSS-AI16...

In this example, the Rosemount 3031C was selected for the sensor and a generic HART Multiplexer

3. Now select the appropriate device and logic configuration settings for your design.

Process Connection	Sensor Device	Interface 1	Interface 2
None	Rosemount 3051C / 3051L, SW ...	Pepperl+Fuchs Standstill Controll...	Pepperl+Fuchs TB-HONSS-AI16...
Configuration Options		PLC Detection Configuration	
Logic Trip Detection :	High	Under/Over Range Alm:	Yes
Sensor Alarm :	Over Range	Filter Alarm:	Yes
		Alarm Vote to Trip:	Yes
		External Comparison:	No

4. Select the **SE Advanced** button

Sensor Group 1 SE Advanced

Group 1 Name :

Measurement Types :

<input type="checkbox"/> Fire and gas	<input type="checkbox"/> Flow measurement	<input type="checkbox"/> Level measurement
<input type="checkbox"/> Other measurement	<input checked="" type="checkbox"/> Pressure measurement	<input type="checkbox"/> Proximity measurement
<input type="checkbox"/> Temperature measurement		

Sensor Voting :  Proof Test Interval (Mo.) :   
 Proof Test Coverage (%) :

Process Connection	Sensor Device	Interface 1	Interface 2
None	Rosemount 3051C / 3051L, SW ...	Generic HART Multiplexer	None

5. Note the DU values for each device. In the example interface 1 = 26, Interface 2 = 6 and the Sensor = 37

Advanced Data				
Device Details				
LEG1				
Process Connection	Input Interface	Sensor Device		
Device	DD	DU	SD	SU
Pepperl+Fuchs Standstill Controller (LB,SC = ON)	0	26	20	93
Pepperl+Fuchs TB-HONSS-AI16-TSHART-1620MA	0	6	109	21

  

Process Connection	Input Interface	Sensor Device		
Device	DD	DU	SD	SU
Rosemount 3051C / 3051L, SW Rev 7.0 or above	0	37	356	0

- From the device safety document, locate the amount of proof test coverage that can be claimed for each device. If the device is a Certified Device the supplier is required to provide this data to the end user. If the device is not required, the user will need to determine the value to use based on historical or general industry data.
- On the [Proof Test Calculator](#) page, enter the data as defined.

Sensor Element		
Overall Proof Test Coverage		Normal
		95.2%
Element	DU (FITs)	PTC
Process Connection	0.0	0%
Sensor Device	37.0	92%
Interface 1	26.0	99%
Interface2	6.0	99%

- In this example, a maximum value 95.2% can be used.

Proof Test Interval (Mo.) :

Proof Test Coverage (%) :

9.